

CERTIFICATE OF COMPLIANCE



Koppers Performance Chemicals Inc.

MicroPro Preservative Technology

10596-420

Certificate Number

01/30/2009 - 01/30/2017

Certificate Period

Certified - Provisional

Status

UL 2818 - 2013 Gold Standard for Chemical Emissions for Building Materials, Finishes and Furnishings

Product tested in accordance with UL 2821 test method to show compliance to emission limits on UL 2818. Section 7.1 and 7.2.

Building products and Interior finishes are determined compliant in accordance with California Department of Public Health (CDPH) Standard Method V.1.1-2010 using the applicable exposure scenario(s).



Environment

GREENGUARD Gold Certification Criteria for Building Products and Interior Finishes

| Criteria | CAS Number | Maximum Allowable Predicted Concentration | Units |
|--|------------|---|-------------------|
| TVOC ^(A) | - | 0.22 | mg/m ³ |
| Formaldehyde | 50-00-0 | 9 (7.3 ppb) | µg/m ³ |
| Total Aldehydes ^(B) | - | 0.043 | ppm |
| 4-Phenylcyclohexene | 4994-16-5 | 6.5 | µg/m ³ |
| Particle Matter less than 10 µm ^(C) | - | 20 | µg/m ³ |
| 1-Methyl-2-pyrrolidinone ^(D) | 872-50-4 | 160 | µg/m ³ |
| Individual VOCs ^(E) | - | 1/2 CREL or 1/100th TLV | - |

- (A) Defined to be the total response of measured VOCs falling within the C₆ – C₁₆ range, with responses calibrated to a toluene surrogate.
- (B) The sum of all measured normal aldehydes from formaldehyde through nonanal, plus benzaldehyde, individually calibrated to a compound specific standard. Heptanal through nonanal are measured via TD/GC/MS analysis and the remaining aldehydes are measured using HPLC/UV analysis.
- (C) Particle emission requirement only applicable to HVAC Duct Products with exposed surface area in air streams (a forced air test with specific test method) and for wood finishing (sanding) systems.
- (D) Based on the CA Prop 65 Maximum Allowable Dose Level for inhalation of 3,200 µg/day and an inhalation rate of 20 m³/day
- (E) Allowable levels for chemicals not listed are derived from the lower of 1/2 the California Office of Environmental Health Hazard Assessment (OEHHA) Chronic Reference Exposure Level (CREL) as required per the CDPH/EHLB/Standard Method v1.1 and BIFMA level credit 7.6.2 and 1/100th of the Threshold Limit Value (TLV) industrial work place standard (Reference: American Conference of Government Industrial Hygienists, 6500 Glenway, Building D-7, and Cincinnati, OH 45211-4438).



Environment